

CERTIFICATE OF COMPLIANCE

Certificate Number E465038
Report Reference E465038-20131101
Date 2021-November-18

Issued to: BARTEC F.N. S.R.L.
Via Mario Pagano 3
Trezzano S/Naviglio MI 20090 IT

**This is to certify that
representative samples of**

CONDUIT FITTINGS FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E465038
Report Reference E465038-20131101
Date 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL - Fittings for use in Class I, Zone 1, AEx d IIC Gb, AEx e IIC Gb; Zone 21, AEx tb IIIC Db IP66 Hazardous Locations.


- Model LBY; followed by 16, 26, 36, or 56; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model NP; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A or B.
- Model EM; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model PLG; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A, B, C or D.
- Model ELF, ELM, or ELMF; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model RE, REM, REB, or REN; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A, B, C or D.

Drain/Vent Fittings – Class I, Zone 1, AEx e IIC Gb; Zone 21, AEx tb IIIC Db IP66 Hazardous Locations.

- Model V; followed by 1; followed by N or M; followed by X

CNL - Fittings for use in Class I, Zone 1, Ex d IIC Gb, Ex e IIC Gb; Class II, Groups E, F, and G Hazardous Locations.

- Model LBY; followed by 16, 26, 36, or 56; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model NP; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A or B.
- Model EM; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model PLG; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A, B, C or D.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



CERTIFICATE OF COMPLIANCE

Certificate Number E465038
Report Reference E465038-20131101
Date 2021-November-18

- Model ELF, ELM, or ELMF; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON
- Model RE, REM, REB, or REN; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by 1, 2, 3, 4, 5, 6, 7 or 8; followed by N, M, or G; followed by AL, X, AZ, OT, or ON; followed by A, B, C or D.

Drain/Vent Fittings – Class I, Zone 1, Ex e IIC Gb; Class II, Groups E, F, and G Hazardous Locations.

- Model V; followed by 1; followed by N or M; followed by X

Standards:

UL 60079-0 & CSA-C22.2 No. 60079-0:11 - Explosive atmospheres – Part 0: Equipment – General requirements

UL 60079-1 - Electrical Apparatus for Explosive Gas Atmospheres – Part 1: Flameproof Enclosures “d”

UL 60079-7 & CSA C22.2 No. 60079-7:12 - Explosive Atmospheres – Part 7: Equipment protection by increased safety “e”

ANSI/ISA-60079-31-2009 - Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure “t”

CSA-C22.2 No. 60079-1:11 - Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d”

CSA C22.2 No. 60079-31:12 - Electrical Apparatus for Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure “t”



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

