

CERTIFICATE OF COMPLIANCE

Certificate Number E465037
Report Reference E465037-20131023
Date 2021-November-18

Issued to: BARTEC F.N. S.R.L.
Via Mario Pagano 3
Trezzano S/Naviglio MI 20090 IT

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E465037
Report Reference E465037-20131023
Date 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL Control Station Enclosures for use in Class I, Zone 1, AEx e IIC; Zone 21, AEx tb IIIC IP66 Hazardous Locations

Enclosure Models ESA1313, ESA1717, ESA2212, ESA2216, ESA2222, ESA3322, ESA3333, ESA4433, ESA4422, ESA4936, ESA5242, ESA6348, ESA7440; may be followed by S

Enclosure Models ESX1313, ESX1414, ESX1717, ESX2212, ESX2216, ESX2222, ESX2614, ESX3322, ESX3333, ESX4422, ESX4433, ESX4040, ESX5040, ESX4936, ESX5242, ESX6020, ESX6348, ESX7440

Enclosure Models GWR09, GWR11, GWR14, GWR21, GWR22, GWR42, GWR44, GWR84

CNL Control Station Enclosures for use in Class I, Zone 1 Ex e II; Class II, Groups E, F, and G Hazardous Locations

Enclosure Models ESA1313, ESA1717, ESA2212, ESA2216, ESA2222, ESA3322, ESA3333, ESA4433, ESA4422, ESA4936, ESA5242, ESA6348, ESA7440; may be followed by S

Enclosure Models ESX1313, ESX1414, ESX1717, ESX2212, ESX2216, ESX2222, ESX2614, ESX3322, ESX3333, ESX4422, ESX4433, ESX4040, ESX5040, ESX4936, ESX5242, ESX6020, ESX6348, ESX7440

Enclosure Models GWR09, GWR11, GWR14, GWR21, GWR22, GWR42, GWR44, GWR84


Standards:

UL 60079-0 & CSA-C22.2 No. 60079-0:11 - Explosive atmospheres – Part 0: Equipment – General Requirements

ISA 60079-31:2009 & CSA C22.2 No. 60079-31:2012 - Electrical Apparatus for Explosive Atmospheres – Part 31 Equipment Dust Ignition Protection by Enclosure “t”

UL 60079-7 & CSA C22.2 No. 60079-7:12 - Explosive Atmospheres – Part 7: Equipment protection by increased safety “e”

UL 508 & CSA C22.2 No. 14-13 - Industrial Control Equipment



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

