



中国国家强制性产品认证证书



证书编号：2020322313000987

认证委托人名称： 博太科防爆设备（上海）有限公司
 认证委托人地址： 上海市闵行区浦江高科技园区新骏环路188号7号楼101、401
 生产者名称： BARTEC GmbH
 生产者地址： Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称： BARTEC GmbH
 企业地址： Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 产品名称： 操作和指示元件
 系列、规格、型号： 05-0003-00 系列
 标 准： GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式：型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求，特发此证。产品相关信息详见附件。

发证日期：2023年04月17日

有效期至：2025年09月02日

首次发证日期：2020年09月03日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313000987

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd
ADDRESS: 101, 401, New Building 7, No. 188, Xinjun Ring Rd.,
 Shanghai Pujiang Hi-Tech Park(Pu Dong Area),
 Minhang District,Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCT: Control and signalling device adapters
SERIES,SPECIFICATION,MODEL: 05-0003-00 series
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

Valid from:April 17, 2023

Valid until:September 2, 2025

Date of original certification:September 3, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007466



中国国家强制性产品认证证书



证书编号: 2020322313000987

附件

产品名称: 操作和指示元件

型号规格: 05-0003-00 a / b, 其中
a 代表设备种类, 可选代码为: 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 82.

Product description	Type reference	Product description	Type reference
Pushbutton	05-0003-0007/****	Position selector	05-0003-0064/****
Emergency button	05-0003-0008/****	Illuminated button	05-0003-0065/****
Position selector	05-0003-0009/****	Illuminated button	05-0003-0066/****
Position selector	05-0003-0010/****	Illuminated button	05-0003-0067/****
Position selector	05-0003-0011/****	Illuminated button	05-0003-0068/****
Lock	05-0003-0012/****	Illuminated button	05-0003-0069/****
Lamp module operator	05-0003-0013/****	Position selector	05-0003-0070/****
Lamp module operator	05-0003-0014/****	Position selector	05-0003-0071/****
Lamp module operator	05-0003-0015/****	Position selector	05-0003-0072/****
Lamp module operator	05-0003-0016/****	Position selector	05-0003-0073/****
Lamp module operator	05-0003-0017/****	Double push button actuator	05-0003-0074/****
Mushroom pushbutton	05-0003-0018/****	Double push button actuator	05-0003-0075/****
Blanking plug	05-0003-0019/****	Potentiometer	05-0003-0076/****

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322313000987

附件

Position selector	05-0003-0020/****	Key switch	05-0003-0077/****
Position selector	05-0003-0021/****	Key switch	05-0003-0078/****
Lock	05-0003-0061/****	Key switch	05-0003-0079/****
Position selector	05-0003-0062/****	Key switch	05-0003-0080/****
Position selector	05-0003-0063/****	Mushroom pushbutton,	05-0003-0082/****

b 为与防爆无关代码。

防爆标志: Ex eb IIC Gb, Ex tb IIIC Db

电气参数: /

相关报告编号: 2023S17402-010926、2020S17402-001460

使用条件:

- 特殊(限制)使用条件:
 - 该产品为 Ex 元件, 与其他电气设备或系统一起使用时需附加认证, 不能单独使用。
 - 产品使用工作温度范围-55℃~+70℃。
- 外壳防护等级 IP64。

批准:



上海仪器仪表自控系统检验测试所有限公司